

**EXHIBIT 34**

Joe Laydon &lt;laydonj@grafton-ma.gov&gt;

---

**155 George Hill - Revised plans**

---

Jeffrey Walsh &lt;JWalsh@gravesengineering.com&gt;

Fri, Aug 9, 2019 at 3:29 PM

To: Andrew Baum &lt;abaum@summitinc.com&gt;, Joe Laydon &lt;laydonj@grafton-ma.gov&gt;

Cc: Leah Cameron &lt;cameronl@grafton-ma.gov&gt;, Mike Lotti &lt;mlotti@industriaeng.com&gt;, Richard McCarthy &lt;rmccarthy@industriaeng.com&gt;, Glenn McGillicuddy &lt;gmccgillicuddy@industriaeng.com&gt;, "Nick Kondek (nkondek@summitinc.com)" &lt;nkondek@summitinc.com&gt;

Joe and Leah,

I have no issue with the proposed 4' W x 2' H culvert at the new project entrance as depicted on Sheets 8, 14 and 19 of the plans last revised August 2, 2019.

I recommend that the Phase 1 construction sequence on Sheet 11 be updated to reference when the culvert will be installed. I assume that the intention would be to install it as part of item #3.

Thanks,

Jeff

JEFFREY M. WALSH, P.E.

Principal

**GRAVES ENGINEERING, INC.**

100 GROVE ST | WORCESTER, MA 01605

T 508-856-0321 ext 109 | F 508-856-0357

gravesengineering.com

**RECEIVED****AUG - 9 2019****PLANNING BOARD  
GRAFTON, MA**

---

**From:** Andrew Baum <abaum@summitinc.com>**Sent:** Monday, August 05, 2019 3:59 PM**To:** Joe Laydon <laydonj@grafton-ma.gov>**Cc:** Leah Cameron <cameronl@grafton-ma.gov>; Jeffrey Walsh <JWalsh@gravesengineering.com>; Mike Lotti <mlotti@industriaeng.com>; Richard McCarthy <rmccarthy@industriaeng.com>; Glenn McGillicuddy <gmccgillicuddy@industriaeng.com>; Nick Kondek (nkondek@summitinc.com) <nkondek@summitinc.com>**Subject:** Re: 155 George Hill - Revised plans

Joe/Leah

[Quoted text hidden]

[Quoted text hidden]